# **Kidde ECS Fire Suppression System Component Description**



## **Electric Control Head**

K-90-8010 Rev BA

### **FEATURES**

For Use with UL Listed, ULC Listed and FM Approved Systems

#### P/N: WK-890181-000



### **Ordering Information**

Part Number	Control Head		
	Voltage	Current	
WK-890181-000	24 VDC	2.0A	

### COMPATIBILITY

Series	For Use With
Kidde ECS HFC-227ea	Х
Kidde ECS Advanced Delivery FM-200®	х

This literature is provided for informational purposes only. KIDDE-FENWAL, INC. assumes no responsibility for the product's suitability for a particular application. The product must be properly applied to work correctly.If you need more information on this product, or if you have a particular problem or question, contact KIDDE-FENWAL, Inc.

FM-200 is a registered trademark of E.I. du Pont de Nemours and Company. Kidde is a registered trademark of Kidde-Fenwal Inc. All other trademarks are the property of their respective owners.

> Kidde Fire Systems 400 Main Street Ashland, MA 01721 Ph: 508.881.2000 Fax: 508.881.8920 www.kiddefiresystems.com

# **Kidde ECS Fire Suppression System Component Description**



## **Electric Control Head**

Effective: June 2014

K-90-6011 Rev BA

### **FEATURES**

For Use with UL Listed, ULC Listed and FM Approved Systems

#### P/N: WK-890181-000



Part Number	Control Head	
	Voltage	Current
WK-890181-000	24 VDC	2.0A

## COMPATIBILITY

Series	For Use With
Kidde ECS HFC-227ea	х
Kidde ECS Advanced Delivery FM-200 <sup>®</sup>	х

This literature is provided for informational purposes only. KIDDE-FENWAL, INC. assumes no responsibility for the product's suitability for a particular application. The product must be properly applied to work correctly. If you need more information on this product, or if you have a particular problem or question, contact KIDDE-FENWAL Inc.

FM-200 is a registered trademark of E.I. du Pont de Nemours and Company. Kidde is a registered trademark of Kidde-Fenwal Inc. All other trademarks are the property of their respective owners.

> Kidde Fire Systems 400 Main Street Ashland, MA 01721 Ph: 508.881.2000 Fax: 508.881.8920 www.kiddefiresystems.com